

Certificate of Conformity

Certificate Number: CN-PV-210039

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specifications /standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen Growatt New Energy Co., Ltd. 2F and 3F, Building 4, Jiayu Company Industrial Park, Xibianling, Shangyu Village, Shiyan Street, Bao'an District, Shenzhen, Guangdong, China
Product:	PV Grid inverter
Ratings & Principle Characteristics:	See Appendix to Certificate of Conformity
Models:	MID 10KTL3-X, MID 12KTL3-X, MID 15KTL3-X, MID 17KTL3-X, MID 20KTL3-X, MID 22KTL3-X, MID 25KTL3-X
Brand Name:	Growatt
Tested according to:	C10/11: ed.2.1, 01 Sep 2019 SPECIFIC TECHNICAL PRESCRIPTIONS REGARDING POWER-GENERATING PLANTS OPERATING IN PARALLEL TO THE DISTRIBUTION NETWORK Type approved for type A
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China
Test Reports No:	200615201GZU-001, Revision 1: 02 Mar 2021

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 04 March 2021

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-210039

Ratings & Principle Characteristics:

Maximum d.c. input voltage: 1100 Vdc
Input voltage range: 160-1000Vdc
MPPT voltage range (full Load): 280-850 V (for MID 10KTL3-X, MID 12KTL3-X); 420-850 V (for MID 15KTL3-X); 480-850 V (for MID 17KTL3-X, MID 20KTL3-X); 520-850 V (for MID 22KTL3-X, MID 25KTL3-X);
Max. input current: 2×27A (for the models except MID 25KTL3-X) ,27/40.5A (for MID 25KTL3-X)
PV Isc: 2×33.8A (for the models except MID 25KTL3-X), 33.8/50.7A (for MID 25KTL3-X)
Nominal output voltage: 3W/N/PE 230V/400Vac
Max. output current: 16.1A (for MID 10KTL3-X); 19.3A (for MID 12KTL3-X); 24.2A (for MID 15KTL3-X); 27.4A (for MID 17KTL3-X); 31.9 A (for MID 20KTL3-X); 35.5A (for MID 22KTL3-X); 40.2 A (for MID 25KTL3-X)
Nominal frequency: 50/60 Hz
Max. output power: 10000W (for MID 10KTL3-X); 12000W (for MID 12KTL3-X); 15000W (for MID 15KTL3-X); 17000W (for MID 17KTL3-X); 20000W (for MID 20KTL3-X); 22000W (for MID 22KTL3-X); 25000W (for MID 25KTL3-X)
Max. apparent power: 10000VA (for MID 10KTL3-X); 13300VA (for MID 12KTL3-X); 16600VA (for MID 15KTL3-X); 18800VA (for MID 17KTL3-X); 22000VA (for MID 20KTL3-X); 24400VA (for MID 22KTL3-X); 27700VA (for MID 25KTL3-X)
Power factor range: 0.8leading ~ 0.8lagging
Safety level: Class I
Ingress protection: IP65
Operating temperature range: -25 ~ +60°C
Software Version: TJ1.0

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.